

TEPROMKC GMBH
 Metallkundencenter West
 Ursulastrasse 33-41
 50354 Huerth

INSPECTION CERTIFICATE
Type 3.1 acc. EN 10204
Certificate No : 1000433276
DATE: 04.05.2020
Delivery No : 0085207398

Customer	BEIJER REF AB			Cust's Part No	
Cust's Ref No	0010023462		Quantity		
Our Order No	1200107303 / 10	Quantity	6.240,00 MTR	Inspection Lot	020000618805

Designation	CuT m 009,525x0,80x15000 JF HPO R				
according to	EN 12735-1,R220.				
Material	Cu-DHP				
Chem. Anal.:	CU>99,90-P:0,015-0,040			OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	9,485 - 9,565	9,535	2
Smin	mm	>=0,720	0,740	2
Smax	mm	<=0,880	0,760	2
LENGTH	mm	>=15000	15140	2
OVALITY	mm	<=0,67	0,03	2
Rm	N/mm ²	>=220,0	246,0 - 247,7	2
A50	%	>=40,0	50,3 - 51,8	2
EXPANSION	%	>=30,0	OK	2
C TOT. RES. IN.	mg/dm ²	<=0,38	0,08 - 0,15	2
ECT EN 1971	%	100	OK	-

DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

05.05.2020

Q.C. INSPECTOR

Q.A. MANAGER



 D. SKARMOUTSOS

FORM N3

ISSUE: C

REV: 2

DATE: DEC. 2017

e-mail: info@halcor.com
 website: www.halcor.com
 VAT number: EL094061318

Offices @ Copper Tube Plant (Mailing Address)
 62nd km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry
 60th km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept
 252 Pireos str.
 GR-17778, Tavros, Athens, GREECE
 Tel.: +30 210 4898111, Fax: +30 210 4898397