

TEPROMKC GMBH  
 Metallkundencenter West  
 Ursulastrasse 33-41  
 50354 Huerth

**INSPECTION CERTIFICATE**  
**Type 3.1 acc. EN 10204**

**Certificate No : 1000431756**  
**Delivery No : 0085206276**

**DATE: 14.04.2020**

Customer	<b>BEIJER REF AB</b>		
Cust's Ref No	<b>0010023248</b>	Cust's Part No	
Our Order No	<b>1200106761 / 10</b>	Quantity	<b>2.160,00 MTR</b>
		Inspection Lot	<b>020000615372</b>

Designation	<b>CuT m 012,700x0,80x15000 JF HPO R</b>		
according to	<b>EN 12735-1,R220.</b>		
Material	<b>Cu-DHP</b>		
Chem. Anal.:	<b>CU&gt;99,90-P:0,015-0,040</b>		<b>OK</b>

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	12,660 - 12,740	12,720	1
Smin	mm	>=0,720	0,740	1
Smax	mm	<=0,880	0,770	1
LENGTH	mm	>=15000	15140	1
OVALITY	mm	<=0,89	0,20	1
Rm	N/mm <sup>2</sup>	>=220,0	248,4	1
A50	%	>=40,0	48,6	1
EXPANSION	%	>=30,0	OK	1
C TOT. RES. IN.	mg/dm <sup>2</sup>	<=0,38	0,10	1
ECT EN 1971	%	100	OK	-

**DECLARATION OF COMFORMITY**

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

21.04.2020

Q.C. INSPECTOR

Q.A. MANAGER



*[Signature]*  
 D. SKARMOUTSOS

FORM N3

ISSUE: C

REV: 2

DATE: DEC. 2017

e-mail: info@halcor.com  
 website: www.halcor.com  
 VAT number: EL094061318

**Offices & Copper Tube Plant (Mailing Address)**  
 62<sup>nd</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 48111, Fax: +30 22620 48911

**Foundry**  
 60<sup>th</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 53479, Fax: +30 22620 53925

**Domestic Sales Dept**  
 252 Pireos str.  
 GR-17778, Tavros, Athens, GREECE  
 Tel.: +30 210 4898111, Fax: +30 210 4898397